SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

MP Global Products, LLC

2500 Old Hadar Road, P.O. Box 2283, Norfolk, NE, United States

For the following product(s):

Flooring Underlayment:

Insulayment™, Avaire Underlayment

This product meets all of the necessary qualifications to be certified for the following claim:

Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom, private office and single-family residence parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-IAQ-01527

Valid from: November 1, 2015 to October 31, 2016







Robert J. Hrubes, Ph.D., Executive Vice President SCS Global Services 2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA